



SECTION A-A

SECTION B-B

NOTES:

- 1 For general installation details see OPSD 2117.010.
- 2 For duct installation profiles see OPSD 2103.020.
- A Minimum cover for reinforcing steel shall be 35mm external surface, 25mm internal surface.
- B All reinforcing shall be cut to suit openings.
- C All dimensions are in millimetres unless otherwise shown.

REINFORCING TABLE					
Mark	Quant	Size	Length (m)	Mass (kg)	Detail
A1	10	15M	2.48	38.62	Straight
A2	6	15M	1.86	17.52	Straight
A3	52	15M	1.2	17.97	
A4	20	20M	2.45	115.4	Straight
A5	20	20M	2.51	118.22	
A6	36	10M	1.78	50.3	Straight
A7	13	15M	2.82	57.55	
A8	10	15M	2.22	34.85	
A9	4	15M	1.0	6.28	Straight

ONTARIO PROVINCIAL STANDARD DRAWING

Apr 2022

Rev 2

**ELECTRICAL MAINTENANCE HOLE
PRECAST CONCRETE
1800 x 2400mm**



OPSD 2111.050