



NOTES:

- 1 When sidewalk is continuously adjacent, the dropped curb at entrances shall be reduced to 75mm.
- 2 For slipforming procedure a 5% batter is acceptable.
- A Treatment at entrances shall be according to OPSD 351.010.
- B Outlet treatment shall be according to the OPSD 610 Series.
- C The transition from one curb type to another shall be a minimum length of 3.0m, except in conjunction with guide rail where it shall be according to the OPSD 900 Series.
- D All dimensions are in millimetres unless otherwise shown.

ONTARIO PROVINCIAL STANDARD DRAWING

Nov 2012 | Rev | 2

CONCRETE BARRIER CURB



OPSD 600.110