



Note: The MUNI implemented in November 2017 replaces OPSS 2479 COMMON, November 2015 with no technical content changes.

MATERIAL SPECIFICATION FOR FLOODLIGHT LUMINAIRES USED IN HIGH MAST LIGHTING

TABLE OF CONTENTS

2479.01	SCOPE
2479.02	REFERENCES
2479.03	DEFINITIONS - Not Used
2479.04	DESIGN AND SUBMISSION REQUIREMENTS
2479.05	MATERIALS
2479.06	EQUIPMENT - Not Used
2479.07	PRODUCTION
2479.08	QUALITY ASSURANCE
2479.09	OWNER PURCHASE OF MATERIAL

APPENDICES

2479-A	Commentary
---------------	-------------------

2479.01 SCOPE

This specification covers the requirements for high mast floodlight luminaires with integral ballast for use in high mast lighting.

2479.01.01 Specification Significance and Use

This specification has been developed for use in municipal-oriented Contracts. The administration, testing, and payment policies, procedures, and practices reflected in this specification correspond to those used by many municipalities in Ontario.

Use of this specification or any other specification shall be according to the Contract Documents.

2479.01.02 Appendices Significance and Use

Appendices are not for use in provincial contracts as they are developed for municipal use, and then, only when invoked by the Owner.

Appendices are developed for the Owner's use only.

Inclusion of an appendix as part of the Contract Documents is solely at the discretion of the Owner. Appendices are not a mandatory part of this specification and only become part of the Contract Documents as the Owner invokes them.

Invoking a particular appendix does not obligate an Owner to use all available appendices. Only invoked appendices form part of the Contract Documents.

The decision to use any appendix is determined by an Owner after considering their contract requirements and their administrative, payment, and testing procedures, policies, and practices. Depending on these considerations, an Owner may not wish to invoke some or any of the available appendices.

2479.02 REFERENCES

When the Contract Documents indicate that provincial-oriented specifications are to be used and there is a provincial-oriented specification of the same number as those listed below, references within this specification to an OPSS shall be deemed to mean OPSS.PROV, unless use of a municipal-oriented specification is specified in the Contract Documents. When there is not a corresponding provincial-oriented specification, the references below shall be considered to be to the OPSS listed, unless use of a municipal-oriented specification is specified in the Contract Documents.

When the Contract Documents indicate that municipal-oriented specifications are to be used and there is a municipal-oriented specification of the same number as those listed below, references within this specification to an OPSS shall be deemed to mean OPSS.MUNI, unless use of a provincial-oriented specification is specified in the Contract Documents. When there is not a corresponding municipal-oriented specification, the references below shall be considered to be the OPSS listed, unless use of a provincial-oriented specification is specified in the Contract Documents.

This specification refers to the following standards, specifications, or publications:

CSA Standards

C22.2 No. 9.0-96 (R2011) General Requirements for Luminaires
C863-11 Energy Efficiency of High-Intensity Discharge (HID) and Low-Pressure Sodium (LPS) Lamp Ballasts

2479.04 DESIGN AND SUBMISSION REQUIREMENTS

2479.04.01 Design Requirements

2479.04.01.01 Photometric Requirements

Photometric test results shall be provided for the floodlight type luminaire supplied and shall include the following data:

- a) Isolux curves and mounting height correction factors.
- b) Utilization charts or graphs indicating the total beam utilization.
- c) Candlepower distribution curves indicating peak intensity.
- d) Luminous intensity tables to Illuminating Engineering Society format (I-tables).
- e) Luminaire efficiency values.
- f) Lamp lumen outputs and wattages.

2479.04.01.02 Electrical Requirements

All electrical components and assembled luminaires shall be according to CSA C22.2 No. 9.0.

Ballasts, lamp sockets, ground connectors, internal wiring, and all other components shall be suitable for the supply voltage as specified in the Contract Documents and the maximum temperature encountered in totally enclosed, outdoor, weatherproof luminaires.

Ballasts shall be constant wattage auto-transformer or isolated secondary transformer type for grounded systems. Auto-transformer type ballasts shall have a maximum tolerance of 12% variation in lamp wattage for a 5% variation in line voltage. Isolated secondary transformer type ballasts shall have a maximum tolerance of 12% variation in lamp wattage for a 10% variation in line voltage.

Ballasts shall be of Class H, 180 °C insulation; 60 hertz; and low temperature, -35 °C with a power factor not less than 0.90.

The minimum nominal secondary open circuit voltage of the ballast for various lamps shall be sufficient to provide reliable starting at -35 °C.

Ballasts shall be suitable for the lamp's nominal operating voltage. Terminal blocks shall be held rigidly and shall provide a positive connection for terminating the field wiring.

Energy efficiency of lamp ballasts shall be according to CAN/CSA C863.

2479.04.01.03 Mechanical Requirements

The luminaire housing shall be cast aluminum or heavy-duty sheet aluminum. The ballast shall be integral. All external fasteners and associated hardware shall be stainless steel. The luminaire shall be provided with a built-in aiming device.

Mounting arrangements shall be trunnion type or slip fitter for a 50 mm diameter internal pipe size tenon with provisions for vertical and horizontal adjustment. The luminaire shall be complete with all external fasteners and associated hardware required for the aiming of the luminaire and attachment to the slip fitter or mounting pad.

The optical assembly shall consist of a specular high purity anodized aluminum reflector. The reflector shall be precision formed and assembled in a way that the formed contour is maintained when it is removed from the luminaire housing. The optical assembly shall be sealed with a high temperature neoprene or silicone rubber gasket located between the door frame and luminaire housing.

When required and as specified in the Contract Documents, a secondary reflector or louvre shall be provided inside the sealed optical assembly. The louvre shall effectively screen the lamp from direct view and provide a cut-off 10° above the peak intensity on the vertical plane.

The door assembly shall consist of a gasketed door frame and a clear tempered shock-resistant glass lens and shall be hinged to the luminaire housing. The luminaire shall be accessible with tool-less entry.

The lamp socket shall be a mogul type with a porcelain-enclosed, nickel-plated brass shell rated for 4,000 volts, and spring-loaded centre contact. The lamp holder shall have an electrically insulated lamp stabilizer and shall hold the lamp's outer envelope in precise alignment with suitable means for vibration damping.

The luminaire assembly when closed and in the operating position shall not be subject to damage by vibration.

2479.04.02 Submission Requirements

2479.04.02.01 Working Drawings

Three copies of Working Drawings shall be submitted to the Contract Administrator a minimum of 14 Days prior to the commencement of fabrication.

As a minimum, the Working Drawings shall include the following information:

- a) Detailed dimensioned layout, including plans, elevations, and weight.
- b) Photometric curve data.
- c) Details of optical system.

Each Working Drawing shall be sealed and stamped by an Engineer certifying that the Working Drawings comply with the Contract Documents.

One copy of the final accepted Working Drawings shall be returned to the supplier, along with written notification to commence fabrication. Within 14 Days of receipt of notification to commence fabrication, the supplier shall submit 3 copies of all final accepted Working Drawings to the Contract Administrator.

Fabrication of the equipment shall not commence until the Working Drawings have been accepted by the Contract Administrator.

Once fabrication of the equipment has commenced, materials and dimensions shown on the final accepted Working Drawings shall not be changed.

2479.05 MATERIALS

2479.05.01 Marking

A permanent non-corrosive nameplate shall be attached to the exterior of the luminaire and located so that the marking is clearly visible during relamping. The nameplate shall indicate the manufacturer's name or trademark, catalogue number, electrical rating, input amperes, luminaire voltage, date of manufacture, and the vertical and horizontal beam distribution.

A permanent label shall be attached to the interior of the luminaire indicating the manufacturer's name or trademark, catalogue number, date of manufacture, and the American National Standards Institute (ANSI) or Illuminating Engineering Society (IES) photometric classification and distribution type; the suitable supply voltage and frequency; the lamp type; the lamp wattage; and the nominal operating voltage of the lamp so that it is clearly visible during maintenance operations.

A label including a wiring diagram shall be attached to each ballast showing the ballast schematic wiring diagram and shall be visible during maintenance operations.

For asymmetrical luminaires with adjustable optical systems, a permanent embossed identification mark shall be located on the luminaire that is clearly visible and identifiable as an orientation mark.

2479.07 PRODUCTION

2479.07.01 Ballast Assemblies

Ballast assemblies shall be factory pre-wired with all connections clearly marked and identified.

2479.07.02 Lamp Socket Positions

The lamp socket position shall be pre-set at the factory for the specified distribution.

2479.08 QUALITY ASSURANCE

2479.08.01 Inspection

The supplier shall notify the Owner of the date that the fabrication of the luminaires is to commence.

The Owner's representative shall have free access to the place of fabrication for the purpose of inspecting and examining plant records, certificates, materials used, fabrication process, and to make any tests as may be considered necessary, while the luminaires are being fabricated.

All luminaires are subject to an inspection by the Owner's representative prior to shipment.

2479.09 OWNER PURCHASE OF MATERIAL

2479.09.01 Packaging and Shipment

The supplier shall provide 3 copies of the luminaire ballast engineering data and shielding data such as material type, gauge thickness, and mounting arrangement to the Owner.

Each luminaire shall be shipped complete with hardware suitably packaged to ensure that all parts are delivered as an entity. A complete parts list shall be included in the shipment. All cartons shall be marked with the ANSI or IES luminaire classification and distribution types.

The supplier is responsible for loading, delivery, and off-loading of luminaires to designated areas. Luminaires shall be subject to inspection during and on completion of off-loading. If any damage to the luminaires is encountered during the inspection, the supplier shall be responsible for the necessary corrective measures subject to the approval of the Owner.

The supplier shall advise the Owner 3 Working Days prior to the shipping date of the intent to deliver and confirm that arrangements for off-loading have been made.

2479.09.02 Measurement and Payment

For measurement purposes, a count shall be made of the number of floodlight luminaires delivered and accepted.

Payment at the price specified in the purchasing order shall be full compensation for the supply and delivery of the floodlight luminaires to the destination at the date and time specified.

The cost of all testing, except that performed in the Owner's laboratory, shall be included in the price.

**Appendix 2479-A, November 2017
FOR USE WHILE DESIGNING MUNICIPAL CONTRACTS**

Note: This is a non-mandatory Commentary Appendix intended to provide information to a designer, during the design stage of a contract, on the use of the OPS specification in a municipal contract. This appendix does not form part of the standard specification. Actions and considerations discussed in this appendix are for information purposes only and do not supersede an Owner's design decisions and methodology.

Designer Action/Considerations

The designer should specify the following in the Contract Documents:

- Supply voltage to the luminaires. (2479.04.01.02)

The designer should determine if the following is required and, if so, specify it in the Contract Documents:

- Secondary reflector or louvre requirements. (2479.04.01.03)

The designer should ensure that the General Conditions of Contract and the 100 Series General Specifications are included in the Contract Documents.

For Owner purchase of material, the following technical information should be given to the supplier in the purchasing order:

- a) Nominal line voltages.
- b) Lamp wattages.
- c) Lamp types and ANSI designations.
- d) Ballast types.
- e) Mounting arrangements.
- f) Luminaire classifications and distribution types.
- g) Photometric curves or test report numbers.
- h) Luminaire vertical and horizontal beam distribution.
- i) Contract layout drawings.

Related Ontario Provincial Standard Drawings

OPSD 2453.060 High Mast Lighting Pole, Flood Light Luminaire Mounting Details