



- NOTES:**
- 1 Slope of ramp shall not exceed 8%.
 - 2 Cross slope of ramp shall not exceed 2% in either direction.
 - 3 Cross slope of flared side of ramp shall not exceed 8%.
 - 4 Dropped curb at ramp shall be modified to eliminate 30 mm step at gutter.
 - 5 Accessible pedestrian signal to have tactile arrow that aligns with direction of crosswalk.
 - 6 Minimum thickness of ramp is 200mm. Minimum thickness of sidewalk and flared sides adjacent to ramp is 150mm.
- A Where only one crosswalk is present at an intersection, only one curb ramp is required.
 B All dimensions are in millimetres unless otherwise shown.

ONTARIO PROVINCIAL STANDARD DRAWING		Nov 2015	Rev 1	
<h1>CONCRETE SIDEWALK RAMPS AT SIGNALIZED INTERSECTIONS</h1>		-----		

OPSD 310.030				