



CROSS SECTION

NOTES:

- 1 Either the square or round stem shall be used with specified connections.
- A Valve stem and valve shall be placed plumb.
- B Stem guide is required if the unsupported length exceeds 2.0m.
- C All dimensions are in millimetres unless otherwise shown.

ONTARIO PROVINCIAL STANDARD DRAWING

Nov 2018

Rev 4

VALVE OPERATOR



OPSD 1101.020