



NOTES:

- 1 Placement and length of downspout as specified.
- A Drains shall be hot dip galvanized after fabrication according to ASTM A 123.
- B Anchor studs shall be attached using fusion weld process.
- C Pipe shall be according to ASTM A 53M, Grade B.
- D All welding shall be of a low hydrogen classification and according to CSA W59.
- E All dimensions are in millimetres unless otherwise shown.

ONTARIO PROVINCIAL STANDARD DRAWING

Nov 2014 | Rev | 2

**DECK
DRAINS
WITH SLOPED DOWNSPOUT**



OPSD 3340.102