



NOTES:

- A Wire struts shall be SAE 1030 steel. Coils shall be SAE 1018 steel.
- B Anchor bolts and hardened steel washers shall be according to ASTM A 325.
- C All welding shall be according to CSA W59.
- D The complete anchorage assembly including bolts, nuts, and washers shall be hot dip galvanized according to CAN/CSA G164M.
- E Bolts shall be given a liberal coating of white non-staining grease.
- F A plywood setting template shall be provided for accurate positioning of anchorage within the concrete form.
- G All dimensions are in millimetres unless otherwise shown.

ONTARIO PROVINCIAL STANDARD DRAWING

Nov 2010 Rev 1

**BARRIERS AND RAILINGS
STEEL
SINGLE RAILING ANCHORAGE**



OPSD 3419.150