



**NOTES**

- A Dimensions of steel pipe extension shall match existing pipe dimensions.
- B Steel pipe for drain modification shall be according to ASTM A53M, Grade B.
- C Steel bar shall be according to CSA G40.21, Grade 300W.
- D Welding electrodes shall be of low hydrogen classification and according to CSA W59.
- E After fabrication, modification assembly shall be hot-dip galvanized as specified.
- F Field welds shall be painted with an approved zinc rich paint.
- G All dimensions are in millimetres unless otherwise shown.

ONTARIO PROVINCIAL STANDARD DRAWING	Apr 2022	Rev 3	
<b>DECK DRAINS</b>			
WITH DOWNSPOUT MODIFICATION FOR ADDITION OF ASPHALT TO EXISTING STRUCTURE			
<b>OPSD 3340.200</b>			