



FRONT VIEW

SIDE VIEW

NOTES:

- 1 Junction box may be Type P4, surface mounted, or Type P2 or P4, embedded.
- 2 If ceiling of structure is not flat, T bracket shall be attached to the ceiling using a wedge mounting bracket as shown in OPSD 2310.030.
- A This OPSD shall be read in conjunction with OPSD 2310.020.
- B Stainless steel hexagonal head machine bolts of a size to suit luminaire mounting holes, nuts, and lockwashers shall be used to mount luminaire to bracket.
- C Conduit entry into the luminaire may vary.
- D All dimensions are in millimetres unless otherwise shown.

ONTARIO PROVINCIAL STANDARD DRAWING		Nov 2016	Rev 1	
UNDERPASS LUMINAIRE CEILING MOUNTED INSTALLATION WITH T BRACKET				
		OPSD 2310.010		