


NOTES:

- 1 For installation of ducts see OPSD 2123.030.
 - 2 Cover shall be retained with 2-12mm dia x 20mm long stainless steel hex head machine bolts that shall be flush with top of cover when fastened.
 - 3 Frame shall be attached using 3-10mm dia x 38mm long machine bolts anchored in concrete wall.
 - 4 One ground lug for #6 AWG stranded copper shall be attached to one frame bolt.
- A For general installation see OPSD 2117.020.
 B All dimensions are in millimetres unless otherwise shown.

ONTARIO PROVINCIAL STANDARD DRAWING	Nov 2017	Rev 0	
ELECTRICAL HANDHOLE PRECAST CONCRETE WITH COVER 460mm DIAMETER			
OPSD 2112.020			